



Lead Testing Results Table

Roaring Brook Elementary School, Chappaqua School District					
Sample Collection Date	Sample ID	Floor	Location	Lead Level (ppb)	Actions Taken
10/2/2020	001-CAF-KF-P-01	1	Kitchen, Faucet 1	1.29	Not Applicable
10/2/2020	001-CAF-KF-P-02	1	Kitchen, Faucet 2	5.71	Not Applicable
10/2/2020	001-CAF-KF-P-03	1	Kitchen, Faucet 3	4.36	Not Applicable
10/2/2020	001-CAF-KF-P-04	1	Kitchen, Faucet 4	1.82	Not Applicable
10/2/2020	001-CAF-KF-P-05	1	Kitchen, Faucet 5	7.57	Not Applicable
10/2/2020	001-CAF-KF-P-06	1	Kitchen, Faucet 6	16.80	Replaced the faucet. Confirmation sampling performed. See below.
10/2/2020	001-120-NS-P-01	1	Room 120, Nurse's office faucet 1	3.12	Not Applicable
10/2/2020	001-122-CF-P-01	1	Room 122, Classroom faucet 1	1.24	Not Applicable
10/2/2020	001-124-CF-P-02	1	Room 124, Classroom faucet 2	2.67	Not Applicable
10/2/2020	001-126-CF-P-03	1	Room 126 Classroom faucet 3	ND	Not Applicable
10/2/2020	001-128-CF-P-04	1	Room 128, Classroom faucet 4	ND	Not Applicable
10/2/2020	001-130-CF-P-05	1	Room 130, Classroom faucet 5	ND	Not Applicable
10/2/2020	001-131-CF-P-06	1	Room 131, Classroom faucet 6	ND	Not Applicable
10/2/2020	001-129-CF-P-07	1	Room 129, Classroom faucet 7	ND	Not Applicable



Lead Testing Results Table

Roaring Brook Elementary School, Chappaqua School District					
Sample Collection Date	Sample ID	Floor	Location	Lead Level (ppb)	Actions Taken
10/2/2020	001-125-CF-P-08	1	Room 125, Classroom faucet 8	2.69	Not Applicable
10/2/2020	001-123-CF-P-09	1	Room 123, Classroom faucet 9	1.30	Not Applicable
10/2/2020	001-121-CF-P-10	1	Room 121, Classroom faucet 10	2.18	Not Applicable
10/2/2020	BSMT-FAW4-CF-P-11	Basement	FAW4, Classroom faucet 11 (L)	ND	Not Applicable
10/2/2020	BSMT-FAW4-CF-P-12	Basement	FAW4, Classroom faucet 12 (R)	2.62	Not Applicable
10/2/2020	BSMT-FAW1B-BF-P-01	Basement	FAW1B, Classroom faucet 1	ND	Not Applicable
10/2/2020	BSMT-CCW307-CF-P-13	Basement	CCW307, Classroom faucet 13	ND	Not Applicable
10/2/2020	002-201-CF-P-14	2	Room 201, Classroom faucet 14	ND	Not Applicable
10/2/2020	002-203-CF-P-15	2	Room 203, Classroom faucet 15	3.58	Not Applicable
10/2/2020	002-205-CF-P-16	2	Room 205, Classroom faucet 16	3.20	Not Applicable
10/2/2020	002-207-CF-P-17	2	Room 207, Classroom faucet 17	1.73	Not Applicable
10/2/2020	002-209-CF-P-18	2	Room 209, Classroom faucet 18	ND	Not Applicable
10/2/2020	002-211-CF-P-19	2	Room 211, Classroom faucet 19	1.72	Not Applicable
10/2/2020	002-212-CF-P-20	2	Room 212, Classroom faucet 20	2.81	Not Applicable



Lead Testing Results Table

Roaring Brook Elementary School, Chappaqua School District					
Sample Collection Date	Sample ID	Floor	Location	Lead Level (ppb)	Actions Taken
10/2/2020	002-210-CF-P-21	2	Room 210, Classroom faucet 21	ND	Not Applicable
10/2/2020	002-208-CF-P-22	2	Room 208, Classroom faucet 22	1.00	Not Applicable
10/2/2020	002-206-CF-P-23	2	Room 206, Classroom faucet 23	1.75	Not Applicable
10/2/2020	002-202-CF-P-24	2	Room 202, Classroom faucet 24	2.00	Not Applicable
10/2/2020	001-101-CF-P-25	1	Room 101, Classroom faucet 25	2.49	Not Applicable
10/2/2020	001-103-CF-P-26	1	Room 103, Classroom faucet 26	9.04	Not Applicable
10/2/2020	001-105-CF-P-27	1	Room 105, Classroom faucet 27	8.51	Not Applicable
10/2/2020	001-107-CF-P-28	1	Room 107, Classroom faucet 28	1.41	Not Applicable
10/2/2020	001-109-CF-P-29	1	Room 109, Classroom faucet 29	8.70	Not Applicable
10/2/2020	001-111-CF-P-30	1	Room 111, Classroom faucet 30	ND	Not Applicable
10/2/2020	001-112-CF-P-31	1	Room 112, Classroom faucet 31	3.59	Not Applicable
10/2/2020	001-110-CF-P-32	1	Room 110, Classroom faucet 32	1.15	Not Applicable
10/2/2020	001-108-CF-P-33	1	Room 108, Classroom faucet 33	2.63	Not Applicable
10/2/2020	001-106-CF-P-34	1	Room 106, Classroom faucet 34	3.54	Not Applicable



Lead Testing Results Table

Roaring Brook Elementary School, Chappaqua School District					
Sample Collection Date	Sample ID	Floor	Location	Lead Level (ppb)	Actions Taken
10/2/2020	001-104-CF-P-35	1	Room 104, Classroom faucet 35	1.32	Not Applicable
10/2/2020	001-102-CF-P-36	1	Room 102, Classroom faucet 36	1.17	Not Applicable
Resample					
11/6/2020	01-CAF-KF-SSP-06	1	Kitchen, Faucet 6	51.8	Further flushing of new equipment performed. Confirmation sampling performed. See below.
12/3/2020	01-CAF-KF-SSP-06	1	Kitchen, Faucet 6	2.13	Not Applicable